



Gloucester Boulevard
PORT KEMBLA, NSW 2505, Australia

Telephone: 1800 804 631

Website: www.kembla.com.au

ABN: 13 003 762 641

14th November 2014.

CERTIFICATE OF COMPLIANCE

AS 2896 – 2011

Medical Gas Systems – Installation and testing of non flammable gas pipeline systems

and

AS/NZS 1571 - 1995

Seamless Copper Tubes for Air conditioning and Refrigeration

Medical gas systems installed and tested to AS 2896 -2011 require copper piping to be constructed with tube to Australian and New Zealand Standard AS/NZS 1571-1995 with dimensions not less than that specified in AS 1432 for Type B tube. AS/NZS 1571 tube for medical gas applications shall be compatible with oxygen, clean and free from oil and grease and particulate matter.

This is to certify that material ordered from Kembla® and identified as the above specification have been manufactured and tested in accordance with the requirements of AS/NZS 1571-1995. The tubes are factory cleaned, degreased and capped prior to delivery and are suitable for use in medical gas piping systems.

MM Kembla, has been accredited by SAI Global Limited, of Australia, as a Quality Endorsed Company, to ISO 9001:2008 (Licence No. QEC 0002/01) and, as such, has a quality management system in place that ensures all product complies with the relevant specification.

Yours Faithfully,

A handwritten signature in black ink, appearing to read 'Bryce Haley', written over a light blue horizontal line.

Bryce Haley
Materials Engineer

